



JSA Architects, Inc.
1314 Ave. Q
Lubbock, Texas 79401
806.370.4550

Addendum Number Two

Issue Date: April 10, 2024

Project: Lubbock County
ITB 240401 CRTC Roof Replacement



The following are additions and changes to the Specifications and Drawings and shall become a part of the Contract Documents. Where items in the Specifications or Drawings are supplemented below, all original requirements shall remain in effect.

Clarification

- Item #1C:** The new flute fill roof insulation shall match the existing trapezoidal rib height as detailed on Detail D9.
- Item #2C:** The existing roof structure is composed of steel purlins.

END OF ADDENDUM ONE – TOTAL PAGES: 1